

PRE-INSULATED ANNEALED COPPER PAIRCOIL





USAGE

- Split system air conditioners
- All sizes suitable for R410A refrigerant
- Condensation prevention

STANDARD PAIRCOIL

With a tough exterior surface for easy installation.

- Backed by MM Kembla's reputation for quality, service and customer care for 100 years.
- Easy installation. No glue, tape or messy powder.
- 20m rolls of pre-insulated copper paircoils allows you to install your pipework in less than half the time of conventional methods.
- UV protection.
- Resistance to abrasion and wear and tear.
- Can be pushed through tight spaces without being caught or torn.



PHYSICAL DIMENSIONS

Kembla product code	Copper tube outside diameter x wall thickness (mm)	Copper tube outside diameter (inches)	R-Values	Paircoil length (m)	Total pack weight (kg)	Carton dimensions (cm)	Cartons per pallet
G99515	6.35 x 0.81 - 9.52 x 0.81	1/4 - 3/8	0.2	20	8.19	59 x 18 x 61	24
G99525	6.35 x 0.81 - 12.70 x 0.81	1/4 - 1/2	0.2	20	9.92	65 x 18 x 67	24
G99535	6.35 x 0.81 - 15.88 x 1.02	1/4 - 5/8	0.2	20	13.37	73 x 18 x 75	8
G99555	9.52 x 0.81 - 15.88 x 1.02	3/8 - 5/8	0.2	20	15.12	77 x 23 x 79	6
G99565	9.52 x 0.81 - 19.05 x 1.14	3/8 - 3/4	0.2	20	18.30	80 x 23 x 82	6

COPPER TUBE SAFEWORKING PRESSURE (kPa)

Copper Tube Dimensions Metric (mm)	@50°C	SWP (kPa) @65°C	@75°C
6.35 x 0.81	10,635	9,545	8,820
9.52 x 0.81	6,800	6,105	5,640
12.70 x 0.81	4,995	4,480	4,140
15.88 x 1.02	5,030	4,515	4,170
19.05 x 1.14	4,697	4,181	3,895

BCA COMPLIANCE

Pipe Insulation

Meets the requirements of insulation material in accordance with AS/NZS 4859.1.

The requirements for Insulation on pipes as outlined in Specification J5-2(d) (BCA Vol 1) and Part 3.12.5 (BCA Vol 2). The BCA requires only total material R-Values be used. For R-Values greater than R1.1 contact our customer service centre to discuss your specific project requirements.

Copper

Manufactured to AS/NZS1571. Recommended maximum operating temperature is 65°C and in accordance with AS1677. A/C manufacturer's operating and installation instructions should be consulted.


INSTALLATION

- Kembla PairCoil copper tube is recommended to be flare jointed. If brazing is necessary, all safety precautions should apply. Refer to installation instruction included with each Kembla PairCoil carton.
- If tight bending is required, the insulation can be cut back to accommodate a tube bender. Alternatively a length of polyethylene tube can be inserted to prevent kinking.

CAUTION: Product data, design details, performance figures, advice and other information given herein (the "Information") is provided only as a guide to available information. MM Kembla does not accept any liability whatsoever (including arising from negligence) for the accuracy of the Information and for injuries, expense or loss, which may arise as a result of the use of the Information by the recipient.

INSULATION PROPERTIES

Material	Highly flexible paired, cross linked, closed cell polyethylene
Thermal Conductivity	0.037 W/m.K at 20°C
Tensile Strength	34.2 (3.49)min N/cm2 (kgf/cm2)
Water Absorption	0.0076 max g/100cm2
Thickness Shrinkage (%)	5% max @(120 ± 5°C)
Coefficient of moisture permeability	10 (0.005) max (per 25mm in thickness) ng/m2∙s∙Pa (g/m2∙h∙mmHg)
Working Temperature	Up to 120°C



😢 KEMBLA

MM, Kembla, MM Kembla and PairCoilMAX are trademarks of Metal Manufactures Ltd

For further information please contact your MM Kembla representative, customer service or visit our website.

MM Kembla, ABN 13 003 762 641 Gloucester Boulevarde, PO BOX 21, Port Kembla, NSW 2505 T: 1800 804 631 F: 1800 817 846 E: sales@kembla.com.au www.kembla.com.au

MM Kembla New Zealand

20B Trugood Drive, East Tamaki, Auckland, 2013 PO Box 51 525, Pakuranga, Auckland, 2140 T: +64 9 274 0111 F: +64 9 274 0347 E: sales@kembla.co.nz www.kembla.co.nz

Technical Bulletin No: D63/16



Endorsed Company ISO 9001 Lic. 002/01 SAI Global